

MCB Instructions


Installation Instruction

This product **MUST** be installed by a licensed electrician.

Line and Load can be top or bottom.

To avoid damage to MCB, disconnect before insulation testing.

Connect the Neutral cable for the circuit before connecting the Line active cable.




	L: 14mm S: (1-25)mm ²
	Recommended 1.5Nm


Applications:

- Used in domestic installations as well as commercial electrical distribution systems.
- Protection of circuits against short-circuit currents
- Protection of circuits against overload currents
- Isolation Switch suitability (variants with red toggles denoted with R at the end)



Mounting




TH35-7.5 DIN rail



Dismounting



Status Indication



WARNING: If MCB trips, it may be caused by either overload or short circuit. The Installation should be checked before resetting MCB.