

# RCBO Instructions

## Installation Instruction


This product **MUST** be installed by a licensed electrician.

Line and Load can be top or bottom.

To avoid damage to RCBO, disconnect before insulation testing.

Connect the Neutral cable for the circuit before connecting the Line active cable.


	L: 12mm S: (1-10)mm <sup>2</sup>
	Recommended 1.5Nm



## Applications:


- Used in domestic installations as well as commercial electrical distribution systems.
- Protection of circuits against short-circuit currents.
- Protection of circuits against overload currents.
- Protection of circuits against earth leakage currents.

## Mounting




TH35-7.5 DIN rail

## Dismounting



## Status Indication



**WARNING:** If RCBO trips, it may be caused by overload, short circuit or earth leakage. The installation should be checked before resetting RCBO.